

**Intertek****ETL SEMKO****VERIFICATION OF LISTING**

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**  
525 9<sup>th</sup> Street S.E.  
Mason City, IA 50401

REPORT REFERENCES: J98021012-231; J98023595-231

This is to certify that representative assemblies of:

**POLYSTYRENE CORE SWINGING TYPE FIRE DOORS, MODEL 707**

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C (1998) "Standard for Positive Pressure Fire Tests of Door Assemblies"  
UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"  
BS 476  
NFPA 252-1995  
UL 10B (1997)  
ASTM E152-81a  
CAN4-S104-1980 (R1985)

Additional Information:

20, 18, or 16 gauge 4'0" x 8'0" single swing doors, 8'0" 8'0" pairs of doors swinging in the same direction, and 6'0" x 8'0" pairs of doors swinging in the opposite direction (double egress) rated up to and including 3 hours. 8'0" x 8'0" double egress doors are allowed with a maximum rating of 1-1/2 hours. Vertical rod exit devices required on both doors. **No intumescent material required.**

Listed mortise or cylindrical locks and rim or mortise panic devices may be used with single swing doors. Listed mortise locks, cylindrical locks, mortise panics, surface mounted vertical rod exit devices, and surface mounted flush bolts may be used on pairs of doors. Rim exit devices with listed hardware or hollow metal mullion may be used on pairs of doors. 24" x 24" louvers and 48" x 48" metal kick plates may be used. Curries or listed vision light kits may be installed.

Pairs with 3 hour ratings must have either Z astragal or a flat astragal. An astragal is optional for pairs with 20 minutes, 3/4, 1, and 1-1/2 hour ratings. See Figures Flat Astragal with Optional Hardware Reinforcing, and "Z" Astragal with Optional Hardware Reinforcing.

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek - Warnock Hersey Listing and Follow-Up Service.

By:

  
Rick Curkeet, Chief Engineer  
Intertek, Building Products Group

**Intertek Testing Services NA, Inc.**  
8431 Murphy Drive, Middleton, WI 53562  
Telephone: 608-836-4400 Fax: 608-836-0050  
Web: [www.intertek-etlsemko.com](http://www.intertek-etlsemko.com)