

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
 525 9th Street S.E.
 Mason City, IA 50401

**Intertek/Warnock Hersey Positive Pressure Frame Glazing Chart
 For use with CURRIES Fire Rated Window Frames and Transom
 Side Light Frames**

GLASS TYPE, BRAND OR DESCRIPTION	RATING	MAX EXPOSED AREA SQ. IN.	MAX WIDTH INCHES	MAX HEIGHT INCHES	GLASS THICKNESS INCHES	MIN. STOP HEIGHT INCHES	MIN. POCKET WIDTH INCHES
Listed Wire Glass	20 min w/o hose	5268	109-3/4	109-3/4	1/4	5/8	3/8
Listed Wire Glass	20 & 45 minute	1296	54	54	1/4	5/8	3/8
Central/Asahi or Pilkington Wire glass with Pemko FG3000	20 & 45 minute	4704	106	106	1/4	5/8	7/16
Firelite, Firelite Plus, or Firelite NT (Technical Glass)	20 min w/o hose	3325	95	95	See Note 1	5/8	See Note 1
Firelite, Firelite Plus, or Firelite NT (Technical Glass)	20, & 45 minute	3325	95	95	See Note 1	5/8	See Note 1
Firelite, Firelite Plus, or Firelite NT (Technical Glass)	60 minute	2721	77	77	See Note 1	5/8	See Note 1
Note 1: Firelite and Firelite NT are 3/16" thick, 3/8" minimum pocket width. Firelite Plus is 5/16" thick, 1/2" minimum pocket width.							