

Intertek

ETL SEMKO

VERIFICATION OF LISTING

ISSUED: May 5, 2005

ISSUED TO: **CURRIES Division of AADG, Inc.**
525 9th Street S.E.
Mason City, IA 50401

REPORT REFERENCES: J99006003-231

This is to certify that representative assemblies of:

TRANSOM PANEL AND SIDE PANEL FRAMES

have been investigated by Intertek-Warnock Hersey and have been found to be in compliance with the standard(s) indicated on this certificate:

Standards:

UL 10C (1998) "Standard for Positive Pressure Fire Tests of Door Assemblies"
UBC 7-2-1997 (Part 1) "Fire Tests of Door Assemblies"
BS 476
NFPA 252-1995
UL 10B (1997)
ASTM E152-81a
CAN4-S104-1980 (R1985)

Additional Information:

12, 14, and 16 gauge Fire Door Frames in masonry walls having a maximum overall size of 13'6" wide by 12'0" high, and in drywall walls having a maximum overall size of 12'0" wide by 11'7-1/2" high, are rated up to and including 3 hours.

Polystyrene, Steel-Stiffened, Temperature Rise, or 1/2" Composite Core Panels with a maximum size of 4'0" wide by 8'0" high for Side Panels and 8'0" wide by 4'0" high for Transom Panels may be used.

Only those products bearing the Warnock Hersey registered certification mark should be considered as being covered by the Intertek – Warnock Hersey Listing and Follow-Up Service.

By:



Rick Curkeet, Chief Engineer
Intertek, Building Products Group

Intertek Testing Services NA, Inc.
8431 Murphy Drive, Middleton, WI 53562
Telephone: 608-836-4400 Fax: 608-836-0050
Web: www.intertek-etlsemko.com